

Technischer Hinweis – Merkblatt DVGW G 408 (M) August 2022

**Conversion of Gas Pipelines made of Plastic Pipes for the
Distribution of Hydrogen-containing High-Methane Gases and
Hydrogen up to 16 bar Operating Pressure**

Umstellung von Gasleitungen aus Kunststoffrohren bis 16 bar
Betriebsdruck für die Verteilung von wasserstoffhaltigen methan-
reichen Gasen und Wasserstoff

H₂ Ready

GAS

The DVGW is the technical and scientific association of gas and water engineers and comprises approximately 14,000 members. For 160 years, the DVGW has been setting the technical standards for the safe, secure and reliable supply of gas and water, actively initiating the exchange of ideas and information in the gas and water sectors and encouraging and promoting on-going progress in the sectors through practical guidance.

The DVGW is an independent non-profit organisation free from economic lobbyism and political influence.

The DVGW Set of Rules is a key instrument for the DVGW to meet its statutable purpose and accomplish its tasks. The DVGW Set of Rules notably defines, on the basis of statutory regulations, the requirements on technical safety, hygiene, environmental protection, fitness for use and consumer protection and organisation for the supply and use of gas and water. The DVGW Set of Rules ensures that the DVGW complies with the statutory principle of self-responsibility of the utilities, for the benefit of technical safety and hygiene as well as environmental and consumer protection.

Note for users

The DVGW Set of Rules rests on the following principles:

- The DVGW Set of Rules has been elaborated in an honorary capacity in accordance with the applicable principles (DVGW Constitution, Rules of Procedure GW 100). On the basis of jurisdiction, both the content and the technical information can be assumed to be correct.
- Everybody can use the DVGW Set of Rules. Duties and obligations may arise from legal or administrative regulations or from a contract or from other legal grounds.
- Nobody can abdicate their responsibility for correct action when applying the DVGW Set of Rules. Anyone applying the DVGW Set of Rules shall ensure its correct application in each concrete case.
- While the DVGW Set of Rules is not the only source of knowledge when looking for professional solutions, it does constitute an important source of such knowledge. It cannot however cover all possible special cases that may require more comprehensive or restrictive measures.

Warning

This English-language version is an informal translation from the German original. However, only the original German language version has been exclusively authorised by the DVGW and its Technical Bodies. The DVGW reserves the right to revise this version at any time due to possible translation errors.

Anybody is free to use the DVGW system of rules. Users are responsible for the proper use of the DVGW system of rules in each individual case.

ISSN 0176-3490

Price group: 2

© DVGW, Bonn, May 2023

DVGW German Technical and Scientific Association for Gas and Water

Josef-Wirmer-Straße 1–3
D-53123 Bonn

Phone: +49 228 9188-5
Fax: +49 228 9188-990
Email: info@dvgw.de
Internet: www.dvgw.de

Reprinting and photomechanical reproduction, also of excerpts, is only permitted with the approval of the DVGW e. V., Bonn.

Distribution: Wirtschafts- und Verlagsgesellschaft Gas und Wasser mbH, Josef-Wirmer-Str. 3, D-53123 Bonn
Phone: +49 228 9191-40 · Fax: +49 228 9191-499
Email: info@wvgw.de · Internet: shop.wvgw.de
Art.No.: 312321 G

Conversion of Gas Pipelines made of Plastic Pipes for the Distribution of Hydrogen-containing High-Methane Gases and Hydrogen up to 16 bar Operating Pressure

Content

Preface 4

1	Scope of Application	5
2	Normative References	5
3	Terms, Symbols, Units and Abbreviations	6
3.1	Conversion	6
4	Grading of Networks and Recommended Actions for the Conversion of Networks	6
4.1	General	6
4.2	Grading Networks with Consideration Towards Hydrogen Concentration and Maximum Allowable Operating Pressure (MOP)	7
4.3	Recommended Actions for Grading and Evaluating Gas Pipelines Made from Plastic for the Operation with Hydrogen-containing, Methane-rich Gases or Hydrogen up to 16 Bar	7
5	Documentation Concerning Construction, Operation, and Maintenance	10
5.1	General	10
5.2	Construction, Operation, and Maintenance Documents	10
6	Construction Elements and Components	10
6.1	General	10
6.2	Declaration of Conformity / Manufacturer Certificate	11
6.3	Permeation / Permeability to Gas of Plastic Pipelines	11
6.4	Flow Controllers in Service Lines	11
7	Hydrogen Compatibility of the Gas Pipeline	12
7.1	General	12
7.2	Pressure Testing of Buried Pipelines	12
7.3	Odorization	13
7.4	Commissioning	13
7.5	Test Certificate	13
7.6	Operation	13
	Annex A (informative) – Specific Gas Values of Methane-Hydrogen Mixtures	15

Preface

This guideline was created by the project group “conversion of gas pipelines” within the Technical Committee “Gas Distribution”.

The energy transition and the ambitious climate goals that the Federal Republic of Germany has set for itself require alternatives to the currently used fossil fuels as well as efficient energy storage technology.

Power-to-gas technology that creates hydrogen by hydrogen electrolysis and electricity application has promising potential for climate protection. In larger quantities, this fuel gas can be used as energy storage and, across sectors, for supplying heating in buildings. In this context, methane-rich gases and hydrogen can be employed.

The already existing gas infrastructure has large potential for the distribution of hydrogen, from the injection point over the distribution network up to the interface with network customers, without requiring more expansive technical changes. Extensive pilot projects with network operators have successfully demonstrated that the existing networks are suitable for the distribution of hydrogen. Both hydrogen-containing, methane-rich gases (2nd gas family) and hydrogen (5th gas family) as specified by DVGW G 260 can be used for the conversion of the network.

The basic prerequisite for the usage of hydrogen-containing, methane-rich gases and hydrogen in the existing gas infrastructure is the technical suitability of the system. This suitability shall be demonstrated prior to conversion.

This requires an examination of the possible changes that the properties of hydrogen might entail, separately from the conversion process. Especially the behaviour of pipeline materials, joints, and valves requires precise testing / precise evaluation to create a basis for the conversion of a gas pipeline to hydrogen-containing, methane-rich gases or hydrogen.

For this reason, “guide rails” have been created in the context of this guideline for orientation during a systematic process for evaluating and converting existing gas distribution networks to operate with hydrogen-containing, methane-rich gases and hydrogen. A specific focus lies on the description of technical aspects and the procedure to determine the suitability of the gas pipeline in terms of materials mechanics.

This Guideline contains the conversion of pipelines pursuant to DVGW Code of Practice G 472 for gas distribution and G 459-1 for service lines.

The requirements of this guideline are, insofar helpful and necessary, aligned with the requirements of DVGW Guideline G 407 “Conversion of Gas Pipelines made of Steel Pipes for the Distribution of Hydrogen-containing High-Methane Gases and Hydrogen up to 16 bar Operating Pressure”.

Earlier Versions

This guideline is a new publication.