



Deutscher Verein des  
Gas- und Wasserfaches e.V.



[www.dvgw-regelwerk.de](http://www.dvgw-regelwerk.de)

# Technical Information – Guideline **DVGW G 655 (M)** April 2021

## **Guideline H2-Readiness Gas Utilisation**

Leitfaden H2-Readiness Gasanwendung

H<sub>2</sub> Ready

GAS

The DVGW is the technical and scientific association of gas and water engineers and comprises approximately 14,000 members. For 160 years, the DVGW has been setting the technical standards for the safe, secure and reliable supply of gas and water, actively initiating the exchange of ideas and information in the gas and water sectors and encouraging and promoting on-going progress in the sectors through practical guidance.

The DVGW is an independent non-profit organisation free from economic lobbyism and political influence.

The DVGW Set of Rules is a key instrument for the DVGW to meet its statutable purpose and accomplish its tasks. The DVGW Set of Rules notably defines, on the basis of statutory regulations, the requirements on technical safety, hygiene, environmental protection, fitness for use and consumer protection and organisation for the supply and use of gas and water. The DVGW Set of Rules ensures that the DVGW complies with the statutory principle of self-responsibility of the utilities, for the benefit of technical safety and hygiene as well as environmental and consumer protection.

### **Note for users**

The DVGW Set of Rules rests on the following principles:

- The DVGW Set of Rules has been elaborated in an honorary capacity in accordance with the applicable principles (DVGW Constitution, Rules of Procedure GW 100). On the basis of jurisdiction, both the content and the technical information can be assumed to be correct.
- Everybody can use the DVGW Set of Rules. Duties and obligations may arise from legal or administrative regulations or from a contract or from other legal grounds.
- Nobody can abdicate their responsibility for correct action when applying the DVGW Set of Rules. Anyone applying the DVGW Set of Rules shall ensure its correct application in each concrete case.
- While the DVGW Set of Rules is not the only source of knowledge when looking for professional solutions, it does constitute an important source of such knowledge. It cannot however cover all possible special cases that may require more comprehensive or restrictive measures.

### **Warning**

This English-language version is an informal translation from the German original. However, only the original German language version has been exclusively authorised by the DVGW and its Technical Bodies. The DVGW reserves the right to revise this version at any time due to possible translation errors.

Anybody is free to use the DVGW system of rules. Users are responsible for the proper use of the DVGW system of rules in each individual case.

ISSN 0176-3490

Price group: 3

© DVGW, Bonn, Juli 2019

DVGW German Technical and Scientific Association for Gas and Water

Josef-Wirmer-Straße 1–3  
D-53123 Bonn

Phone: +49 228 9188-5  
Fax: +49 228 9188-990  
Email: [info@dvgw.de](mailto:info@dvgw.de)  
Internet: [www.dvgw.de](http://www.dvgw.de)

Reprinting and photomechanical reproduction, also of excerpts, is only permitted with the approval of the DVGW e. V., Bonn.

Distribution: Wirtschafts- und Verlagsgesellschaft Gas und Wasser mbH, Josef-Wirmer-Str. 3, D-53123 Bonn  
Phone: +49 228 9191-40 · Fax: +49 228 9191-499  
Email: [info@wvgw.de](mailto:info@wvgw.de) · Internet: [shop.wvgw.de](http://shop.wvgw.de)  
Art.No.: 312678 G

**Contents**

**Preface 5**

**Introduction ..... 7**

**1 Scope ..... 9**

**2 Normative References ..... 9**

**3 Terms, Symbols, Units, and Abbreviations ..... 11**

3.1 Hydrogen-rich Fuel Gases ..... 11

3.2 Hydrogen ..... 11

**4 Gas Properties ..... 11**

4.1 Natural Gases According to DVGW G 260 (A) ..... 11

4.2 Natural Gas/Hydrogen Mixtures up to 10 vol % H<sub>2</sub> ..... 11

4.3 Natural Gas/Hydrogen Mixtures beyond 10 vol % to 20 vol % H<sub>2</sub> ..... 12

4.4 Hydrogen ..... 12

**5 Requirements for Persons and Companies ..... 13**

**6 Requirements for Pipework Components and Materials ..... 13**

6.1 Natural Gas/Hydrogen Mixtures beyond 10 vol % to 20 vol % H<sub>2</sub> ..... 13

6.2 Hydrogen ..... 14

**7 Requirements for Pipework Installation ..... 14**

7.1 Natural Gas/Hydrogen Mixtures beyond 10 vol % to 20 vol % H<sub>2</sub> ..... 14

7.2 Hydrogen ..... 14

**8 Pipework Design ..... 14**

8.1 Natural Gas/Hydrogen Mixtures beyond 10 vol % to 20 vol % H<sub>2</sub> ..... 14

8.2 Hydrogen ..... 15

**9 Gas Appliances ..... 15**

9.1 Natural Gas/Hydrogen Mixtures beyond 10 vol % to 20 vol % H<sub>2</sub> ..... 15

9.2 Hydrogen ..... 15

<b>10</b>	<b>Installation of Gas Appliances / Combustion Air Supply / Exhaust Gas Discharge</b> .....	<b>16</b>
10.1	Natural Gas/Hydrogen Mixtures beyond 10 vol % to 20 vol % H <sub>2</sub> .....	16
10.2	Hydrogen .....	16
<b>11</b>	<b>Industrial Gas Applications</b> .....	<b>16</b>
11.1	Thermoprocessing Equipment .....	16
11.2	Power Plants.....	16
11.3	Chemical Applications .....	17
<b>12</b>	<b>Filling Stations (Fuelling Stations)</b> .....	<b>17</b>
12.1	CNG Filling Stations .....	17
12.2	Hydrogen Filling Stations.....	17
<b>13</b>	<b>Adjustment or Conversion of distributed Gas</b> .....	<b>17</b>
13.1	Adjustment to Hydrogen-rich Gases.....	17
13.1.1	Components and Pipework .....	17
13.1.2	Gas Appliances .....	18
13.1.3	Industrial Gas Applications .....	18
13.2	Hydrogen Conversion.....	18
<b>Annex A (normative) – Dimensioning Tables for Hydrogen – Domestic Applications <i>mutatis mutandis</i> according to DVGW Code of Practice G 600, DVGW-TRGI .....</b>		<b>19</b>
<b>Annex B (normative) – Dimensioning Tables for Industrial Pipework for Hydrogen with an Operating Pressure of up to 100 hPa/mbar (analogous to DVGW Code of Practice G 614-1).....</b>		<b>23</b>
<b>Further Reading .....</b>		<b>30</b>

## Preface

This Guideline was developed by the project group “H<sub>2</sub> Readiness for Gas Installation” within the Technical Committee “Gas Installation” with the involvement of representatives from Technical Committees “Domestic, Commercial, and Industrial Gas Applications”, “Components and Auxiliary Materials – Gas”, as well as of “Infrastructure Gas Mobility”.

According to the German Energy Industry Act (“*Energiewirtschaftsgesetz*”; EnWG) Article 3 No 10c und No 19a the injection of hydrogen and other renewable gases is permissible. In combination with Article 49 of the Energy Industry Act, the DVGW Sets of Rules and, specifically, the technical rules Code of Practice G 260 “Gas Quality”, for domestic installations still G 600 “Technical Rule for Gas Installations” (DVGW TRGI) and G 614-1 “Above-Ground Gas Pipelines on Premises behind Point of Delivery — Design, Construction, Testing and Commissioning” shall be taken into account..

According to DVGW Code of Practice G 262:2011-09 “Usage of Gases from Regenerative Sources in the Supply of the General Public with Gas”, the injection of < 10 vol% hydrogen has been admissible. The revision of DVGW G 260:2020-09 (draft) and entailed fusion with DVGW G 262 (A) has laid the basis for the injection of hydrogen of up to 20 vol%. In principle, the injection with such a volume was already possible through applying a corresponding exception in DVGW G 260 (A):2013 Section 4.2.2 “Relative Density” and carrying out pre-acceptance testing in case values fell below the relative density.

To make “pure” hydrogen networks possible, an amendment of the Energy Industry Act is currently being developed which will integrate pure hydrogen networks into the Act. There, the DVGW Sets of Rules are referenced as the generally accepted state-of-art.

This Guideline further expands the DVGW sets of rules for hydrogen-rich natural gas of up to 20 vol% H<sub>2</sub> or hydrogen in the context of a two-step process.

In the first step, “H<sub>2</sub> Guidelines” are developed for the fields “gas infrastructure” and “gas utilisation” which describe the protection objectives for hydrogen-rich natural gases and hydrogen that must be adhered to and that supplement the existing sets of rules. The goal is to expand the scope of application of DVGW Sets of Rules to natural gas/hydrogen mixtures or pure hydrogen. The process includes advice and recommended actions that make e.g., the realization of pilot projects or conducting individual certified acceptance tests possible.

In the second step, the respective national and European rulesets are revised and adjusted in detail with consideration towards the results of parallelly occurring F&E activities.

In some sections, only generalized specifications or notes are currently possible. As soon as new state of knowledge exists, these generalized items will be specified with more precision.

This Guideline is a first publication.